

CHECK LIST FOR STATIONARY CNG INSTALLATION PROPOSALS

Application received: Date _____

Installation File Name _____

Installer's License No. _____ Qualified Installer YES NO Expires _____

Filing Fee Rec'd \$50 PCN _____ Resub. Fee Rec'd \$30 PCN _____

Type of Installation: _____

Aggregate WC of **current** storage _____ Number of tank(s) to be installed _____

Size of tank(s) to be installed _____ Total WC upon completion _____

Container Information complete YES NO

Mfg's Name: Tank 1 _____, Tank 2 _____, Tank 3 _____

Serial No.: Tank 1 _____, Tank 2 _____, Tank 3 _____

Water Capacity: Tank 1 _____, Tank 2 _____, Tank 3 _____

Year Built: Tank 1 _____, Tank 2 _____, Tank 3 _____

Service Press: Tank 1 _____, Tank 2 _____, Tank 3 _____

Container(s) to be installed: NEW USED BOTH

NOTIFICATION

Certified Survey Plat (identifying property boundaries) Rec'd: Date _____

CNG Form 1500A(s) rec'd: Date _____

INSTALLATION SITE PLAN (check if distance listed meets requirement)

Site plan submitted?

Container location indicated?

Adjacent Container's in Multi-container installation: Listed? Distance _____' 13.94(e) – 3'

Flammable & Class II combustible liquid containers: Distance _____' Table 13.94(d) – (20')

Location of Material Handling Equip.: Listed?

Container & material handing equip. to: See Table 13.94(d)

Property lines: Listed? N _____' S _____' E _____' W _____' – 10'

Buildings: Listed? Distance _____' – 10'

Railroad (nearest rail of a main track): Listed? Distance _____' – 50'

Pipeline: Listed? Distance _____' (no rule requirement for distance)

Roadway ROW: Listed? Distance _____' 10'

Are the container and material handling equip. adequately protected from damage? Yes No 13.93

Container to Elec. Tran. Lines: Listed? Distance _____' 13.94(d) – 6'

Public Ways (streets, thoroughfares, sidewalks): Distance _____' Table 13.94(d) – (10')

Source of ignition/combustible materials: Distance _____' Table 13.94(d) – (10')

Means to prevent the flow or accumulation of liquids: Listed? 13.95(d)

If manifold: location of manually operated shutoff valve: Listed? 13.101(b)

Does the installation include a transfer system? YES NO *Includes dispensing equipment. Point of transfer is defined as, the location where the fueling connection is made.*

If Yes, then the following apply per Table 13.94(d):

Buildings: Distance _____' (10')*

Building openings: Distance _____' (10')

Property lines: Listed? N _____' S _____' E _____' W _____' - 10'

Roadway ROW: Listed? Distance _____' - 10'

Public Ways (streets, thoroughfares, sidewalks): Distance _____' (10')

Railroad (nearest rail of a main track): Listed? Distance _____' 50'

Source of ignition/combustible materials: Distance _____' (10')

Flammable & Class II combustible liquid containers: Distance _____' (20') (Not applicable to dispensing equipment)

Flammable & Class II combustible liquid dispensers: Distance _____' (3')

For Compression and Dispensing Equipment:

Location of Remote ESV: Listed? 13.101(e) *Must be visible from the dispensing area.*

Electrical Equipment see 13.102

Lease agreement required: YES NO Date: _____

Unusual topographical or geographical features? _____

Other activities, features, or safety concerns? _____

Review of Submitted Application (deficiencies noted & listed below):

Action Taken: _____

Current Status of Proposal: _____